

VOC Content Test Certificate

Monday, 24th July 2023

Supplier: RLA Polymers Pty Ltd (215 COLCHESTER RD, KILSYTH, VIC, 3173, AUSTRALIA).

Sample Description: ATA Aus-Mastic

Date Tested: 19 July 2023 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960-05 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960 as detailed for paints as well as South Coast Air Quality Management District (SCAQMD) Rule 1168.

Test Data:

Specification Green Building Council of Australia Green Star Design & As Built V1.3 13.1.1 Green Star Interiors V1.3 12.1.1B	ATA Aus-Mastic Adhesive
General purpose adhesives and sealants: 50 grams per Litre as VOC content per material	36 gram per Litre as VOC content per material
<i>We hereby certify RLA BT 100 Tile Adhesive is below the VOC Content limits of chosen category specified by Green Star Design, Green Building Council of Australia</i>	



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Dr. Tuan Duong
PhD, BE (Chem. Eng.)
Senior Consultant



Travis Hale
BSc (Biotechnology)
Senior Consultant

Issue date: 24/7/2023

Expiry date: 24/07/2028

P23070057