

# VOC Content Test Certificate

Thursday, 18<sup>th</sup> December 2025

Supplier: Australian Tiling Adhesives Pty Ltd (3 Progress Court, LAVERTON NORTH, VIC, 3026, AUSTRALIA).

Product Name: AUS - FLEX MULTI

Date Tested: 12<sup>th</sup> December 2025 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960-05 test method is referred in accordance with the laboratory testing guidance from Green Building Council of Australia

Test Data:

<b>Specification</b> <b>Green Building Council of Australia</b> <b>Green Star Buildings V1 Revision C</b> <b>Exposure to Toxins Credit 13</b>	<b>AUS - FLEX MULTI</b>
<b>General Purpose Adhesives and Sealants Limit:</b> <b>50 grams per litre</b>	<b>2 grams per litre as VOC content per material</b>
<b>Meets GBCA VOC Content Requirement</b>	<b>Yes</b>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Dr. Tuan Duong  
PhD, BE (Chemical Engineer)  
Senior Consultant



Travis Hale  
BSc (Biotechnology)  
Senior Consultant